

TOWN OF VERNON

55 WEST MAIN STREET, VERNON, CT 06066 Tel: (860) 870-3652 Fax: (860) 870-3589

OFFICE OF THE FIRE MARSHAL

E EVENIOUS ISO

The following checklist is designed to serve as a guide for business owners, managers, and property maintenance personnel responsible for preparing for an inspection and ensuring code compliance. This is only a guide and some requirements apply only to specific occupancy types. There are also additional requirements beyond the scope of this guide.

Code references include: the Connecticut State Fire Safety Code (CSFSC), the Connecticut State Fire Prevention Code (CSFSC), Connecticut General Statutes (CGS) Chapter 541, the Connecticut Flammable and Combustible Liquids Code, the Connecticut Gas Equipment and Piping Code, the International Mechanical Code (IMC), and various National Fire Protection Association codes (NFPA 10, 13, 25, 30, 54, 70 and 72).

WEANS OF EGRESS	FIRE EXTINGUISHERS
 □ Exit doors are unlocked □ Exit doors are working properly □ Exits are not obstructed □ Proper aisle widths are maintained 	□ Serviced annually□ Properly mounted□ Accessible
FIRE ALARM SYSTEM (where required)	EMERGENCY LIGHTS / EXIT SIGNS
 ☐ System is ON ☐ System is monitored (where required) ☐ System is tested annually ☐ Copy of most recent test report 	 □ All emergency lights working properly □ All exit signs properly illuminated □ Record of monthly and annual tests
	ELECTRICAL
FIRE SPRINKLER SYSTEM (where required) □ Sprinkler room/riser is accessible □ System is operational □ System is inspected quarterly □ System is tested annually □ Copy of most recent test report □ No storage within 18" of sprinkler heads □ No paint/grease/debris on sprinkler heads □ Escutcheon plates are in place □ Fire department connection is accessible	 □ Main electrical panel is accessible □ Main electrical panel is properly labeled □ No storage within 30" of electrical equipment □ No exposed wires / open electrical boxes □ No extension cords used for permanent wiring □ No extension cords affixed to or extend through walls, ceilings, floors, or under doors or floor coverings □ Extension cords and multi-plug adapters are rated for their applications □ No "piggy backing" of extension cords or multi-plug adapters



TOWN OF VERNON

55 WEST MAIN STREET, VERNON, CT 06066 Tel: (860) 870-3652 Fax: (860) 870-3589

OFFICE OF THE FIRE MARSHAL

COMMERCIAL KITCHENS	
	Class "K" extinguisher present No excessive buildup of grease in hood(s)
	and exhaust duct(s) Hood(s) and exhaust duct(s) are regularly
	.,
	No gaps between grease filters
	Fire suppression pull station accessible Fire suppression system is tested annually Copy of most recent test report
HA	AZARDOUS MATERIALS
	Compressed gas cylinders secured No storage within 36" of oil and gas-fired heating units
MI	SCELLANEOUS
	Acceptable, fire rated wall and ceiling coverings
	Escape plans posted where required Occupant load posted (all assembly occupancies)